

॥ श्री ॥



POOJA FIRE AND SAFETY SYSTEMS

Certified United Central Register of Certification: ISO 9001 2015, SAFE CONTRACTOR, FIRE SPECIALISTS
FIRE SAFETY AND SECURITY CERTIFICATION OF INDIA - SAFE CONTRACTOR - FIRE SERVICE

- Our Products and Services -

Fire Extinguisher, Fire Alarm Detection System, Fire Suppression System (FM200), All Fire Systems, Safety Products & Equipments

CERTIFICATE

TO,

Date:- 07/06/2023

Saraswati Vishwa - Vidyalaya National School Talawade
Gat No. 169, Ganeshnagar Talawade Road
Pune - 411014

TO WHOM SO IT EVER CONCERNED

This is to certify that we have Refilled and HPT the following extinguishers as per BIS norms. IS 2190: 2010 Refilling and HPT Agency Pooja Fire And Safety Systems Temperature (-)30°C to + 60°C Cylinder Testing Pressure 15 bar Chemical Filling Propellant Dry Nitrogen

ABC Powder (Stored Pressure Type)	2 KG	-	02 Nos.
ABC Powder (Stored Pressure Type)	4 KG	-	22 Nos.
ABC Powder (Stored Pressure Type)	6 KG	-	06 Nos.
DCP (Dry Chemical Powder)	5 KG	-	01 Nos.

Refilling Warranty date is valid from 07/08/2023 up to 06/08/2024

ABC HPT valid 3 Year date of Hydraulically Pressure Tested

CARBON DI OXIDE FIRE EXTINGUISHER WHEEL TYPE

TEST PRESSURE (min) : 250 Bar

WORKING PRESSURE : 150 Bar

OPERATING TEMP. C : -20 C to +55

Regards,

For, POOJA FIRE AND SAFETY SYSTEMS

Authorized Signatory

GST No.: 27BXLPG0947F1ZG

Sr. No. 36/1 to 4, Shop No. A/10-05, Kunal Residency, Nr. Barne Corner, Pawar Nagar - 2, Thergaon, Pune - 411 033. MH, India.
MOB : 9552847373 | Email Id : poojafire945@gmail.com | marketing.poojafire@gmail.com



Scanned with OKEN Scanner

॥ श्री ॥



POOJA FIRE AND SAFETY SYSTEMS

Certified United Central Register of Certification: ISO 9001:2015, SAFE CONTRACTOR, FIRE SPECIALISTS
FIRE SAFETY AND SECURITY CERTIFICATION OF INDIA : SAFE CONTRACTOR - FIRE SERVICE

- Our Products and Services -

Fire Extinguisher, Fire Alarm Detection System, Fire Suppression System (FM200), All Fire Systems, Safety Products & Equipments

CERTIFICATE

Date:- 09/08/2023

TO,

Saraswati Vishwa - Vidyalaya National School
Gat No. 169, Ganeshnagar Talawade Road
Pune - 411014

TO WHOM SO IT EVER CONCERNED

This is to certify that we have Refilled the following extinguishers as per
BIS norms.

ABC Powder (Stored Pressure Type)	4 KG	-	01 Nos.
ABC Powder (Stored Pressure Type)	6 KG	-	02 Nos.

Warranty date is valid from 09/08/2023 up to 08/08/2024

Regards,

For, POOJA FIRE AND SAFETY SYSTEMS



Authorized Signatory

GST No.: 27BXLPG0947F1ZG

Sr. No. 36/1 to 4, Shop No. A/10-05, Kunal Residency, Nr. Barne Corner, Pawar Nagar - 2, Thergaon, Pune - 411 033. MH, India.
MOB : 9552847373 | Email Id : poojafire945@gmail.com | marketing.poojafire@gmail.com



Scanned with OKEN Scanner