



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

No - ws/lab/ 2400 /2024

Date - 20/02/2024

To,
Principle,
Saraswati Vishwa Vidyalaya.
International school
Talawade road.

Subject : Water sample Potability Certificate.

Drinking water and tank water sample provided by Saraswati Vishwa Vidyalaya International school Talawade road on Date: 13/02/2024 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no.ws /lab /2391/2024 dated 15/02/2024 & ws /lab /2389/2024 dated 14/02/2024 the water Sample is safe for drinking purpose.

Note-The water sample not drawn by this laboratory.

Chief Chemist (WS)
Pimpri Chinchwad Municipal Corporation
Pimpri -18



PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION

No-WS/LAB2391/2024

Date-15/02/2024


REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME - सरस्वती विश्व विद्यालय
इंटरनॅशनल स्कूल
ADDRESS - लखवडे रोड

DATE OF EXAMINATION -13/02/2024

SOURCE -

| NO. | WATER SAMPLE (PLACE) | RESIDUAL CHLORINE (PPM) | CONCLUSION MPN/100ml | | REMARK |
|-----|----------------------|-------------------------|----------------------|--------|----------|
| | | | Collforms | E.Coll | |
| 1 | Tank water | 0.1 ppm | 0/100ml | - | potable |
| 2 | Pcmc water | 0.3 ppm | 0/100ml | - | potable. |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | | | | | |
| 9 | | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | | | | | |
| 14 | | | | | |
| 15 | | | | | |


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 2387 / 2024

DATE - 14 / 02 / 2024

NAME - सरस्वती विश्व विद्यालय इंटरनॅशनल स्कुल

DATE OF RECEIPT - 13 / 02 / 2024

ADDRESS - नऊवडे रोड

DATE OF EXAMINATION - 14 / 02 / 2024

SOURCE - PCMC Water.

| NO | TESTS | I.S Standards for Drinking Water | Result mg/lit | Result mg/lit | Conclusion |
|----|---------------------------|----------------------------------|---------------|---------------|------------|
| 1 | Turbidity | 1 N.T.U Max | 3.53 NTU. | | |
| 2 | ph | 6.5 to 8.5 | 6.93. | | |
| 3 | Total Hardness (as CaCO3) | 200 mg/lit | 72 mg/lit | | |
| 4 | Chloride | 250 mg/lit | 18 mg/lit | | |
| 5 | Calcium | 75 mg/lit | 14.42 mg/lit | | |

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
Water Treatment Plant
Sector 23 Nigdi

PIMPRI CHINCHWAD MUNICIPAL CORPORATION



(W/S) DIVISION

Report Of Chemical Examination Of Water

NO-WS / LAB / 2389 / 2024

DATE - 14 / 02 / 2024

NAME - सरस्वती विश्व विद्यालय इंटरनॅशनल स्कूल DATE OF RECEIPT - 13 / 02 / 2024


ADDRESS - लळढे रोड

DATE OF EXAMINATION - 14 / 02 / 2024

SOURCE - Tank Water

| NO | TESTS | I.S Standards for Drinking Water | Result mg/lit | Result mg/lit | Conclusion |
|----|--|----------------------------------|---------------|---------------|------------|
| 1 | Turbidity | 1 N.T.U Max | 3.25 NTU. | | |
| 2 | ph | 6.5 to 8.5 | 6.92. | | |
| 3 | Total Hardness (as CaCO ₃) | 200 mg/lit | 84 mg/lit | | |
| 4 | Chloride | 250 mg/lit | 18 mg/lit | | |
| 5 | Calcium | 75 mg/lit | 16.03 mg/lit | | |

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
Water Treatment Plant
Sector 23 Nigdi